



SOILMATE ENGINEERING CONSULTANCY LLP

NABL Accredited Laboratory | An ISO 9001-2015 Certified Company

PLOT NO 19,20, JHULELAL SOCIETY, NEAR JUBILEE CIRCEL, BHUJ, KACHCHH, GUJARAT, 370001.

(M) 9979669944 • E-MAIL : soilmateeng@gmail.com

TEST REPORT

Test Report No: : SMEC/202627/09/174 Date: 28-09-2026

Name of Customer : Christ School

Address of Customer : Airport Ring Road, Bhuj-Kachchh

Name of Client : Christ School

Letter Reference No., Dated : - 23-09-2026

Name of Project : -

Type of Material Received : Drinking Water

Date of Sample Receipt : 23-09-2026

Condition of Sample when Received : OK

Source of Sample & Sample ID : Local

Duration of Sample Testing : 25-09-2026 to 28-09-2026

TEST RESULTS:

SR.NO.	TYPE OF TEST	TEST METHOD	TEST RESULT	IS 10500 : 2012 (Reaffirmed 2023)
1	Total Hardness, mg/l	IS:3025 Part-21: 2009	86	200 mg/l Max.
2	Total Dissolved Solids, mg/l	IS 3025 (Part-16) : 2023	313	500 mg/l Max.
3	Organic Matter, mg/l	IS 3025 (Part-18) : 2022	62	-
4	Inorganic Matter, mg/l	IS 3025 (Part-18) : 2022	149	-
5	pH Value	IS:3025 Part-11:1983	7.40	6.5-8.5
6	Sulphate (as SO ₄) , mg/l	IS 3025 (Part-24/Sec 1) : 2022	75	200 mg/l Max.
7	Chlorides (as Cl) , mg/l	IS:3025 (Part-32) : 1988	179	250 mg/l Max.
8	Total Suspended Solids, mg/l	IS 3025 (Part-17) : 2022	40	-

FOR SOILMATE ENGINEERING CONSULTANCY LLP

Mr. Sumit Budhimbhatti
Testing Engineer

NOTE:

- 1.The Samples have been Submitted by the Customer.
- 2.This Report shall not be Reproduced Except in full, without Approval of the Laboratory.
- 3.Results given above Refer only to the Samples Submitted for Testing.
- 4.Results are issued with specific understanding that Soilmate Engineering Consultancy LLP will not in any case be involved in actions following the interpretation of test results.